



Product Service

# Attestation of Conformity

No. N8A 16 11 81159 068

**Holder of Certificate:** **Zhejiang Wigo Pump Co.,Ltd**

No.288 Dongqiao Middle Road  
Dayangcheng Industrial Zone, Daxi Town  
317525 Wenling City, Zhejiang  
PEOPLE'S REPUBLIC OF CHINA

**Product:** **Circulation pump**

**Model(s):** **RSx/4EAy, RS25/5EAy, RSx/6EAy**  
**(x means different pipe caliber;**  
**y means different appearance;**  
**x=15, 25 or 32; y=blank, B, D, F, K or Q)**

**Parameters:**

Rated voltage:	220-240V~
Rated frequency:	50Hz
Rated input current/power:	RSx/4EAy: 0.19A/22W, RS25/5EAy: 0.26A/32W, RSx/6EAy: 0.38A/45W (x=15, 25 or 32; y=Blank, B, D, F, K or Q)
Protection class:	I
Degree of protection:	IP44
Temperature classification:	TF95

**Tested  
according to:**

EN 60335-2-51:2003/A2:2012  
EN 60335-1:2012/A11:2014  
EN 62233:2008

This Attestation of Conformity is issued on a voluntary basis according to the Low Voltage Directive 2014/35/EU relating to electrical equipment designed for use within certain voltage limits. It confirms that the listed equipment complies with the principal protection requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

**Test report no.:** 704011223602-03

**Date,** 2016-11-11

( Zhiqiang Jin )



After preparation of the necessary technical documentation as well as the EU declaration of conformity the required CE marking can be affixed on the product. The declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.